



#### NOTES

1. CONCRETE STRENGTH TO BE 3,000 PSI, MIN.
2. REINFORCING TO BE ASTM A615, GR. 60.
3. aggregate to be used either Class 6.5-3500-3/4 or Class 6-3500-1-1/2
4. Anchor Bolts shall be min. of 42" long, 1" diameter.

FOUNDATION FOR  
STREETLIGHT POLES